

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245503
Address: 2619 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Monday, April 14, 2025

Corrective Action Required:

1 Misc

- install spark rings on outlets in kitchen backsplash outlets
- remove dust covers from smoke detectors for inspection
- missing arc fault protection on refrigerator and fireplace , afci protection required
- all outlets in unfinished spaces to be gfci protected or single pull receptacle and labeled
- Seal top ac disconnect
- secure ac unit supply whip within 12" of disconnect
- seal all exterior penetrations

Comments: