

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243549  
Address: 1237 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Ready for Temp CO	Monday, April 14, 2025

Corrective Action Required:

1	Misc	-Provide landscaping as required per plot plan -Screw the exterior garage door embedded jamb brace into studs through the four pre-drilled holes with min 3" screws
---	------	--

\*\*TCO was issued on Feb-6. TCO is currently expire and must be extended or will be NOV status. All due fees (2 TCO fees) must be paid

**Comments:**