

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243094
Address: 3222 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Tuesday, April 15, 2025

Informational:

1	Misc	4-7-25 Dustin A, dw is formed and compacted. Approved to pour . 4-15-25 Dustin A, Dw is poured. The saw cuts do not reach joints . Will need to be extended.
---	------	---

Comments: