CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243211

Address: 1542 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

Inspected On: Tuesday, April 15, 2025
Inspected By: Development Center
Expiration Date: 4/12/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until** approved.

Occupancy Inspection - Codes Drew Fischer Ready for Temp CO Tuesday, April 15, 2025

Residential

Corrective Action Required:

1 Misc TCO EXTENSION LETTER UPLOADED AND APPROVED. FOR ANOTHER 30 DAYS.

-ensure address is contrasting in color from back drop or illuminated

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Thursday, January 16,

Residential

Corrective Action Required:

1 Misc TCO EXTENSION LETTER UPLOADED AND APPROVED. FOR ANOTHER 30 DAYS.

- -ensure address is contrasting in color from backdrop
- -final grade and sod
- -water meter needs to be 14"-18" from top of meter to well lid ring(you're at 28") (meter risers must be approved by the water department) you also have 3 meter pit risers. Any conservative meter risers must be approved through water department.

2025

-splash blocks and sump pump discharge to extend 36" from foundation

Occupancy Inspection - Codes Residential Corrective Action Required:		Mitchell Schwarz	Ready for Temp CO	Tuesday, December 24, 2024
1	Misc	-final grade and sod -water meter needs to be 28") (meter risers must be 3 meter pit risers. Any con water department.	water meter needs to be 14"-18" from top of meter to well lid ring(v8") (meter risers must be approved by the water department) you a meter pit risers. Any conservative meter risers must be approved t	

Comments: