

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243632
Address: 1538 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Tuesday, April 15, 2025

Corrective Action Required:

1	Misc	As graded plot plan submitted, but needs 6' of fall on 3 sides of house and storm inlet cleaned. Can see that lot slopes back to house simply by looking at fence. TCO extended for 30 days
---	------	---

Comments: