

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20246426  
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mitchell Schwarz	Failed	Wednesday, April 16, 2025

Corrective Action Required:

1	Misc	-Loading dock not to plans 16x8 spread footing installed(revise plans to show as built) -ufer located between 1st and 2nd 8'x8' piers) headed west off the NE corner -footing and pads from loading dock N then W ending at 5th pad west- okay
---	------	--

**Comments:**