

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245719  
Address: 2230 SW HEARTLAND CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Drew Fischer	Failed	Wednesday, April 16, 2025

Corrective Action Required:  
1 Misc Plans do not specify pier size.  
(2) piers  
1 21"x36" pier E most pier  
1 24"x36" pier W most pier.

Corrective Action Required:  
2 Misc Piers are already poured, please upload 3rd inspection to address

**Comments:**