



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115556, Building Permit - Commercial
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	Mark Harding	Failed	Tuesday, January 03, 2012

Corrective Action Required

1	MISC	PARTIAL- RM 102 4" DRAIN FOR BACKFLOW RM 122 2" SINK
---	------	--

Comments: