

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245058  
Address: 2606 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Partial	Wednesday, April 16, 2025

Corrective Action Required:

1	Miscellaneous Correction	4-2-25 RH. Sidewalk failed due to soft subgrade. 04-16-25 Jamie S, SW is formed, and compacted. The slopes are in compliance with city standards. Approved to pour.
---	--------------------------	--

**Comments:**