

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245643

Address: 1409 SW WINTHROP TER, LEES SUMMIT, MO 64081
1407 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Wednesday, April 16, 2025

Corrective Action Required:

1	Misc	Basement-okay Fire caulk penetrations from ridge in attic
---	------	--

Comments: