



April 16, 2025

City of Lee's Summit Missouri
220 SE Green St.
Lee's Summit, MO 64063

Re: Associated Plastic Surgeons
2701 NE McBaine Dr.
Lee's Summit, MO 64064
Permit No: PRCOM20245463

To whom it may concern:

We are in receipt of City review comments dated 03/27/2025. Listed below are the City comments in **bold** along with our responses in *italics*.

Licensed Contractors

- 1. MEP subcontractors are required to be listed on permit. Provide company names of license MEP contractors.**
The plumbing and electrical subcontractor info below has been forwarded to the City.

*Plumbing subcontractor
Magnum Plumbing
1100 S. Winterbrooke Dr.
Olathe, KS 66062
Contact: Justin Mcaninch*

*Electrical subcontractor
Palmer Electric
6600 Royal St., Suite B
Pleasant Valley, MO 64068
Contact: Mike Graff*

*We will provide Mechanical subcontractor information upon award of contract.
We understand and will comply if mechanical work cannot be performed
before the information is provided to the City.*

Fire Plan Review

- 1. Provide location of emergency lighting other than exits.**
Refer sheet E2.1S. Additional emergency fixtures have been added.
- 2. Provide location of exit lights other than exits.**
Refer sheet E2.1S. Additional emergency fixtures have been added to illuminate the marked exits around the (empty) building shell. Additional exit lights will be incorporated throughout the tenant finish build-out that will be submitted separately.

This concludes our responses to your comments. Please feel free to contact our office with any additional questions or concerns.

Best regards,

A handwritten signature in black ink, appearing to read 'Kevin Campbell', with a stylized, cursive script.

Kevin Campbell

Attachments; Sheet E2.1S-Rev 02