



LIGHTING FLOOR PLAN NOTES

1. NOTE...

LIGHTING FLOOR PLAN
1/8" = 1'-0"
(SHELL)
NORTH

ELECTRICAL GENERAL NOTES

- SEE ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF LIGHT FIXTURES.
- COORDINATE NEMA RATING OF APPLIANCE PLUGS WITH THE EQUIPMENT SPECIFICATIONS.
- ALL RECEPTACLES WITHIN 6' OF WATER BEARING FIXTURES, EXTERIOR OUTLETS AND ALL OUTLETS IN KITCHEN AREAS SHALL BE GFI STYLE OR THE CIRCUIT SERVING THOSE DEVICES SHALL BE PROTECTED BY MEANS OF A GFI CIRCUIT BREAKER.
- OUTLET AND SWITCH BOXES INSTALLED IN RATED WALLS SHALL BE PROVIDED WITH UL LISTED PUTTY PADS TO PROTECT THE RATING OF THE WALL.
- CONNECT ALL NIGHT LIGHT, EXIT LIGHT AND EMERGENCY LIGHT FIXTURES TO UNSWITCHED HOT-LEG OF NEAREST 120V LIGHTING CIRCUIT IN SAME AREA.
- CONDUIT INSTALLED IN AREAS OF BUILDINGS OR PORTIONS OF BUILDINGS WHERE MEDICAL CARE IS PROVIDED SHALL BE MEDICAL GRADE CONDUIT AND THE INSTALLATION SHALL CONFORM WITH CHAPTER 517 OF THE NEC (HEALTH CARE FACILITIES).
- THE ELECTRICAL CONTRACTOR SHALL CONSULT WITH OTHER SUB-CONTRACTORS PROVIDING ENERGIZED EQUIPMENT TO ASSURE THAT ASSOCIATED ELECTRICAL EQUIPMENT MATCHES THE CHARACTERISTICS OF THE EQUIPMENT BEING PROVIDED.

Gladfelter Engineering Group
10233 Millstone Drive, #112
Lenexa, Kansas 66220
Phone: 866-96-4675
Email: ggg@ggg.net



Dev Anand
President & CEO

Kevin Campbell
Senior Architect

8807 Monrovia Street
Lenexa, Kansas 66215

Phone: 913.322.8882
Fax: 913.322.8886
Email: kevin@dev-inc.com

THIS DRAWING has been prepared by the Architect, or prepared under his direct supervision as an instrument of service and is intended for use only on this project. All Drawings, Specifications, ideas and designs, including the overall layout, form, arrangement, and composition of space and elements portrayed, constitute the original, unpublished work of the Architect. Any reproduction, use, or disclosure of the information contained herein without the written consent of the Architect is strictly prohibited.

COMPLY WITH all laws, codes, ordinances and regulations with authorities having jurisdiction and with requirements of the Landlord, if applicable. Do not start work until all permits and required approvals are obtained.

A NEW BUILDING FOR:
ASSOCIATED PLASTIC SURGEONS
1-470 BUSINESS & TECHNOLOGY CENTER
NE McBAIN DRIVE
LEE'S SUMMIT, MISSOURI

PROFESSIONAL ENGINEER
GREGORY P. GLADFELTER
NUMBER E-2000150421
03/06/2025

PROJECT NO. 231206
DRAWING ISSUANCE
06/27/2024 SHELL PERMIT
03/06/2025 CITY COMMENTS
04/11/2025 CITY COMMENTS

SHEET NUMBER
E2.1S
FLOOR PLAN