

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Thursday, April 17, 2025

Corrective Action Required:

1	STAIR TOWER 1	Stair in building F Complete
---	---------------	---------------------------------

Corrective Action Required:

2	STAIR TOWER 2	-Stair in building G Complete
---	---------------	----------------------------------

Corrective Action Required:

3	STAIR TOWER 3	Stair 3 in Building G -Complete
---	---------------	------------------------------------

Corrective Action Required:

4	STAIR TOWER 4	Stair 4 in Building J: complete
---	---------------	------------------------------------

Corrective Action Required:

5	STAIR TOWER 5	Stair at Building K complete
---	---------------	---------------------------------

Corrective Action Required:

6	ELEVATOR 1	Elevator F -1st and 2nd layer unit side behind trusses -1st, 2nd and 3rd layer at ceiling -1st and 2nd layer interior all floors -1st, 2nd layer at unit side -1st and 2nd layer inside at 4th, 3rd, 2nd , 1st floors
---	------------	--

Corrective Action Required: 7	ELEVATOR 2	-1st and 2nd layer inside at 3rd floor  1st layer, 2nd, 3rd layer and hat channel at ceiling 1st and 2nd layer all floors interior 3 walls -1st and 2nd layer outside all floors -1st and 2nd layer at corridor side all floors -1st layer at door side basement, 1st, 2nd, 3rd, 4th floor
Corrective Action Required: 8	FIRST FLOOR	Building F: complete
		Building G: complete
		Building H: complete
		Building J: complete
Corrective Action Required: 9	SECOND FLOOR	Building F: Complete
		Building G: Complete
		Building H: complete
		Building J: complete
Corrective Action Required: 10	THIRD FLOOR	Building F: Complete
		Building G: Complete
		Building H: complete
		Building J: complete
Corrective Action Required: 11	FOURTH FLOOR	Building F: Complete
		Building G: complete

Building H:  
complete

Building J:  
complete

Corrective Action Required:

12        ELEVATOR 3        complete

Corrective Action Required:

13        LOWER LEVEL        Complete

**Comments:**