

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244782  
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, April 18, 2025

Corrective Action Required:

1	Misc	Exterior wall footing: -E.3/8 to J/6.5; H.3/4.9 to D.2/2.2; B.8/1 to A.2/5.8
---	------	---

**\*\*Corrections:**

- Grounding to footing steel not done
- Have engineer address stair tower pad not done per plan

**Comments:**