

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232726
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Devon Perry	Passed	Friday, April 18, 2025

Informational:

1 Misc

3-26-25 DP. The north phase 12" public water line has completed the hydrostatic test. 150psi for 2 hours. The line has been chlorinated.

3-27-25 DP. The line has been flushed.

Comments: