

norm@advancedexcavationllc.com
Devon.perry@cityofls.net
ap@advancedexcavationllc.com

Norm Beachy
Advanced Excavation
1207 W Newton PO Box 398

Versailles, MO 65084

Report Email: norm@advancedexcavationllc.com

Copy Email: Devon.perry@cityofls.net

Lab Report Fax No:

Lab Report Contact 1: (573) 789-6269

Lab Report Contact 2:

Customer ID No: 9343

Customer PO No:

Collected By: Client

Invoice No: 63333

Report of Analysis

Laboratory Report ID No:

20712

Project Name: Discovery Park North Phase 12" Public Water Line

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING	LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD		
1	6191	Bacteria, P/A E. Coli	4/1/25	4/2/25	1	CFU/100mL	Negative CFU/100mL
	139498		Spot 1 Sample 2		SM9223 B		
2	6190	Bacteria, P/A T. Coliform	4/1/25	4/2/25	1	CFU/100mL	Negative CFU/100mL
	139497		Spot 1 Sample 2		SM9223 B		

Comments, if present, concern this Lab Work Order:

The reported analytical results relate only to the sample submitted.

This report shall not be reproduced, except in full, without written approval by Blue Valley Laboratories, Inc.