

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235734
Address: 1901 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	Devon Perry	Passed	Friday, April 18, 2025

Informational:

1	Misc	2-27-25 DP. Aaron's crew with Advanced Excavation cut the 8"x6" tee in today for the fire line and installed a 6" isolation valve. This is all on a private line. The fire line will be shorter than a stick of pipe, which will not require samples.
		4-16-25 DP. This line passed hydrostatic at 200psi for 2 hours.

Comments: