

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Devon Perry	Partial	Friday, April 18, 2025

Informational:

1 Misc

4-14-25 DP. Crew poured sidewalk on the north side of the property that connected to existing. They used AB3 and had adequate amount, compacted. They had expansion join laid out where it needed to go and cross slopes looked to be in compliance. I told them with the SW being so wide, that I will confirm cross slopes on final.

**Comments:**