CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20242722Address:2303 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Sidewalk Inspection		Dustin Agcopra	Partial	Friday, April 18, 2025	
Corrective Action Required:					
1	Misc	meter. We found the lid a	26-25 DP. Before approving any sidewalk inspections locate the water eter. We found the lid and part of the pit in line of where the sidewalk bes. If this is true, builder needs to call plumber and relocate pit and meter orther into yard.		
	3-31-25 DP. SW on east side of house, south side of house DW are formed, aggregate compacted, cross slopes are in conditions can change. Approved to pour. Instead of tying into the ADA ramp that needs replaced, I install a header 5' back from both turn around panels so w the ada ramp at a different time, there will be a full panel add their expansion joint at property line. West side of D			re in compliance but ed, I'm having them so when they go to pour panel where they can	
		4-4-25 Dustin A	stin A t been completed , will need another pre pour inspection.		
Swildshi		Sw has not been complete	u, win need another pre p	our inspection.	
		cannot pour until ada ram 4-11-25 Dustin A, Sw on rig Several sections are not in they are attaching to is cra	o that has to be replaced has p is formed and pre pour ins ght side of approach is form a compliance (over 2%) and acked and has been patched as and cut out crackedsectio	spection is performed. ed and compacted. d the existing section I not to city standards. ,	

4-11-25 Dustin A, section of sidewalk on right side of approach has been fixed, Apprved to pour. Still need to remove ada in the rear of lot and replace. Will need a prepour on that,

Comments: