CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246287

Address: 1344 SW WINTHROP TER, LEES SUMMIT, MO 640811342 SW WINTHROP TER, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Control Inspection Shawn Hoffman Failed Friday, April 18, 2025

Residential

Corrective Action Required:

DCM6 ESC INSP REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED

DENIED STREET IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED

CLEAN UP INSPECTION(S) BEING PERFORMED.

Comments: