

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20115575	Date:	January 04, 2012
Project Title:	TIP TOP TUX	Applicant:	
Location:	880 NW BLUE PKWY, Unit:E LEES SUMMIT, MO 64086	KCFS	
Type of Work:	Alarm Alteration	901 E. Loula	
Occupancy Group:	M	Olathe, KS 66061	
Description:	TENANT FINISH FOR TUX	(913) 720-5237	
RENTAL			
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Alarm Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Plans received 12/28/2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule an alarm test. Tests shall be conducted prior to the regular hours of the neighboring tenants.

3. Duct detector activations shall be handled as supervisory alarms only.

Verified at inspection.