

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250470
Address: 2631 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, April 22, 2025

Corrective Action Required:

1	Misc	PORTAL FRAME AND CS-PF ONLY
		-CS-PF MISSING ONE STRAP
		- PFH SHEETING IS TO HAVE SHEET BREAKS IN THE MIDDLE 2 FT. FROM TOP OF HEADER TO BOTTEM OF SILL PLAE.

Comments: