## LEE'S SUMMIT

#### **DEVELOPMENT SERVICES**

#### PLAN REVIEW CONDITIONS

April 17, 2025

DAVIDSON ARCHITECTURE & ENGINEERING 4301 INDIAN CREEK PKWY OVERLAND PARK, KS 66207

Permit No:	PRCOM20251363
Project Title:	KIDZ FIRST THERAPY
Project Address:	2704 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Parcel Number:	5224006030000000
Location / Legal	LAKEWOOD BUSINESS CENTER ON I-470 - PLAT PLOT 16
Description:	
Type of Work:	CHANGE OF TENANT
Occupancy Group:	BUSINESS
Description:	CHANGE OF TENANT TO KIDZ FIRST THERAPY

#### **Revisions Required**

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Rejected

**Licensed Contractors** 

1. Lee's Summit Code of Ordinance, Section7-130.4 - Business License. (excerpt) No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

**Reviewed By: Joe Frogge** 

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors. (HVAC sub required) 5 Star Mechanical, LLC

Building Plan Review Reviewed By: Joe Frogge Approved with Conditions

1. A one-time impact fee in the form of a license tax must be collected before occupancy can be granted. Please be advised that additional application, review, and inspection fees do apply and additional information pertaining to this will be provided during that stage of your approval process.

Action required: Comment is for informational purposes. After a credit for previouse warehouse use the fee will be \$9,916.50.

Fire Plan Review	Reviewed By: Craig Hill	Rejected	
220 SE Green Street   Lee's Summit, MO 64063  816.969.1200   816.969.1201 Fax   <u>cityofLS.net/Development</u>			
	Dago 1		

# 

#### **DEVELOPMENT SERVICES**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action Required: Provide deferred submittal for fire alarm system. Acknowledged

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action Required: Provide deferred submittal for fire protection system. Acknowledged

3. Add exit signage to be seen in corridors 132 and 137. Acknowledged, signage has been added to lighting plan (1/E1.1).

5. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel. Acknowledged, fire extinguisher locations have been identified on plan (1/A2.1), denoted by construction note 6.

### The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.