

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244782
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Shawn Hoffman	Partial	Tuesday, April 22, 2025

Corrective Action Required:

1	Misc	Exterior wall footing: -E.3/8 to J/6.5; H.3/4.9 to D.2/2.2; B.8/1 to A.2/5.8 Elevator pit 4-4.5 to C.2 Stairs slab pad J-H.5 TO 4.9-6.1 NOT READY: B.9-D.2 to 1.-2.1 **Corrections: -Grounding to footing steel not done -Have engineer address stair tower pad not done per plan
---	------	--

Comments: