

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245537
Address: 2759 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Wednesday, April 23, 2025

Corrective Action Required:

1	Misc	- Seal top of a/c disconnect - Final grading and sod - Provide splash pads - Sump discharge to be 36" away from foundation - Pay all fees
---	------	---

Comments: