

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20250416
Address: 3932 SW FLINTROCK DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Wednesday, April 23, 2025

Corrective Action Required
1 Misc

- CLEAN AND RESTORE PROTECION AT STORM INLET BOX
- PROTECTION OF STOCK PILE REQUIRED
- POST ADDRESS

Corrective Action Required
2 DCM3 ESC REQUIRED 2
DAY

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

4-21-25 Dustin A, Silt fence is down right side of approach
4-23-25 Dustin A, Silt fence has not been repaired.

Comments: