

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251255  
Address: 2250 NW QUARRY PARK RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Robb Popp	Failed	Wednesday, April 23, 2025

Corrective Action Required:

1	Misc	Install 3/0 cu grounding conductor per plan
---	------	---

**Comments:**