

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250281
Address: 2754 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, April 23, 2025

Corrective Action Required:
1 Misc PORTAL FRAME AND FRONT PORCH ONLY
APPROVED

Corrective Action Required:
2 Misc

- Shim short studs in primary bedroom exterior wall near great room
-
- Address H4 truss at entry broken
- I- beam with less than 3" of bearing front wall near bedroom 2

Comments: