

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240118
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, April 23, 2025

Corrective Action Required:

1	FIRST FLOOR	Throughout: -Install all fire dampers -Complete balcony framing -Seal penetrations at corridors Atrium: -Seal penetrations at shaft wall, complete electrical at mailroom, protect storm line, seal plate penetrations, fireblock dead spaces
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR	Throughout: -Complete balcony framing -Seal penetrations at corridors
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	Throughout: -Complete balcony framing -Seal penetrations at corridors
---	-------------	---

Corrective Action Required:

4	FOURTH FLOOR	Throughout; -Complete balcony framing -Seal penetrations at corridors
---	--------------	---

Corrective Action Required:

5 STAIR TOWER 1
Corrective Action Required:
6 STAIR TOWER 2

Comments: