

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235734
Address: 1901 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, April 23, 2025

Corrective Action Required:

1	Misc	Storm drain: -Area B. See deficiency below
---	------	---

Sanitary drain:
-Area B

Corrective Action Required:

2	Misc	Storm drain under two col pads N/6.6 and P.6/6.6 will have to be relocated
---	------	--

Comments: