



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114738, Building Permit - Commercial  
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, January 05, 2012

Partial Correction  
1 MISC

OK TO COVER WHEN READY 5/8" TYPE X CEILING GWB AT FOLLOWING SPACES SPECIFIED AS DOUBLE LAYER BY A/E: 1ST LAYER AT SPACES 109-122; 125;

**Comments:**