

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236587  
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, April 23, 2025

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit and submit backflow valve test report to city -Sidewalk not approved on record -Seal above electrical service meter/disconnect enclosure
---	------	---

Comments: