

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243960
Address: 840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, April 24, 2025

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Install lockouts at sign breakers -Provide ASSE 1022 backflow devices at all carbonated beverage dispensers -Cut drain pipes 2x pipe diameter above floor drains -Provide GFCI protection at kitchen, bar, dishwash and prep areas -Remove exit sign at side door -Provide permanent tag at gas meter -Label exterior electrical disconnect -Install screens at vents on exterior cooler -Label all dedicated non GFCI receptacles -Upload Health Department report -Provide documentation for plastic wall covering -Missing cover plate at J box above dining area
---	------	---

Comments: