## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20250578Address:3133 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Drew Fischer	Failed	Thursday, April 24, 2025
Corrective Action Required:			

Corrective Action Required:

1 Misc Plumbing is ok -Pump out excess water and all organic material must be removed before pouring -call for re-inspection before pouring

Comments: