

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245916

Address: 1408 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1406 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Mitchell Schwarz	Failed	Thursday, April 24, 2025

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -SILT FENCE AT FRONT OF LOT DAMAGED AND DOWN -SPREAD GRAVEL FILTER AT FRONT OF LOT
---	----------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**