

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, April 25, 2025

Corrective Action Required:

1	Misc	-Seal return air space at bedroom/dining double stud wall **Seal gap at top and gaps along studs; fb gap at top of wall
		-Protect csst gas line at entrance into living room fireplace box
		-Provide engineer report for suspended slab
		-Fb basement wall from joist space along east basement exterior wall; seal gap and holes at vertical fire blocking

Comments: