



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113398, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	John Borns	Partial	Friday, January 06, 2012

Partial Correction
1 MISC

OK TO POUR WHEN APPROVED BY SEA PAN DECK STRUCTURE
AT FOLLOWING LEVELS: 4TH FLOOR COMPLETE; 5TH FLOOR
COMPLETE;

Concrete Walls and Columns Inspection	John Borns	Partial	Friday, January 06, 2012
--	------------	---------	--------------------------

Partial Correction
1 MISC

OK TO POUR WHEN READY, CONTINGENT ON S.E.A. APPROVAL,
C.I.P. CONCRETE COLUMNS AT LOCATIONS: 3RD LEVEL; 4TH
LEVEL;
column: DD122,EE10-11-12,M5,N6,P7,K3,J5,H5; H/7; H/9; L/7; L/9;

Comments: