

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245377
Address: 2222 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Monday, April 28, 2025

Corrective Action Required:

1 Misc

- provide additional outlet in garage
(1 outlet per vehicle bay) see E3901.9
- provide spark ring on outlet above the fireplace
- lockout for all hard wired appliances
- not in clear plain sight of panel

Comments: