CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245537

Address: 2759 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Monday, April 28, 2025

Residential

Corrective Action Required:

1 Misc - Seal top of a/c disconnect

Final grading and sodProvide splash pads

- Sump discharge to be 36" away from foundation

- Pay all fees

Comments: