



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115575, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Friday, January 06, 2012

Occupancy Inspection - Codes Commercial	John Borns	Failed	Friday, January 06, 2012
--	------------	--------	--------------------------

Corrective Action Required
1 MISC

SLIPSHEETS UNDER ROOFTOP GAS PIPING SUPPORTS NOT ATTACHED TO BLOCKS; G.C. SUPT WAS ADVISED OF CORRECTION ALTERNATIVES.

Corrective Action Required
2 MISC

ACCESSIBLE-COMPLIANT RECEPTION COUNTER NOT FOUND PROVIDED.

Corrective Action Required
3 MISC

LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. MUST BE UL LISTED/LABELED.

Alarm Test	Joe Dir	Passed	Friday, January 06, 2012
-------------------	---------	--------	--------------------------

Sprinkler - Flow Test	Joe Dir	Passed	Friday, January 06, 2012
------------------------------	---------	--------	--------------------------

**Occupancy
Inspection - Fire**

Joe Dir

Passed

Friday, January 06, 2012

**Comments: OK TO SET UP FOR BUSINESS. NO CUSTOMERS OR PUBLIC UNTIL ADA
COUNTER IS IN PLACE.**