



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRROOF20113687, Roofing Permit

Address: 806 SW BLUE PKWY, LEES SUMMIT, MO 64063818 SW BLUE PKWY, LEES SUMMIT, MO 64063826 SW BLUE PKWY, LEES SUMMIT, MO 64063828 SW BLUE PKWY, LEES SUMMIT, MO 64063834 SW BLUE PKWY, LEES SUMMIT, MO 64063838 SW BLUE PKWY, LEES SUMMIT, MO 64063840 SW BLUE PKWY, LEES SUMMIT, MO 64063846 SW BLUE PKWY, LEES SUMMIT, MO 64063848 SW BLUE PKWY, LEES SUMMIT, MO 64063852 SW BLUE PKWY, LEES SUMMIT, MO 64063856 SW BLUE PKWY, LEES SUMMIT, MO 64063858 SW BLUE PKWY, LEES SUMMIT, MO 64063862 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Roof Final Inspection	John Borns	Partial	Friday, January 06, 2012

Partial Correction
1 MISC

PRELIMINARY FINAL INSPECTION PERFORMED 1/6/12: ARNOLD TO BE CONTACTED RE CONDITION AND SPACING OF EXISTING ROOFTOP GAS PIPING SUPPORTS, CLAMPS, SLIP SHEETS, ETC

Comments: