



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20235208	Date:	April 28, 2025
Project Title:	RESIDENCES AT BLACKWELL -	Applicant:	
BUILDING #4			
Location:		MIDWEST ALARM SERVICES	
2911 SE SHENANDOAH DR, LEES SUMMIT, MO 64063		1910 E KIMBERLY RD STE 200	
Type of Work:		DAVENPORT, IA 52807	
Occupancy Group:	R-2	Primary: (913) 915-6143	
Description:	RESIDENCES AT BLACKWELL -		
BUILDING #4 - 67 Units			
NEW APARTMENT BUILDING			
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

2018 IFC 904.4.2 Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816) 969-1300 24 hours in advance to schedule an alarm test. System must be monitored and pretested before scheduling.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.