

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244782
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|------------------------|
| Footing Inspection - Commercial | Khanh Nguyen | Partial | Monday, April 28, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Exterior wall footing: -E.3/8 to J/6.5; H.3/4.9 to D.2/2.2; B.8/1 to A.2/5.8; completion of remaining ext. footing |
| | | Interior footing: -North and south stair towers pads -Elevator pad -All col. pads |
| | | **Corrections: -Grounding to footing steel not done |

Comments: