

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245945
Address: 204 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Tuesday, April 29, 2025

Corrective Action Required:

1	Misc	-In wall MEPs not complete **OK to cover top of furout wall for hood -Complete plumbing for hand sink, protect dwv in bathroom
---	------	--

Comments: