

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232899  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	Bobby Richest	Partial	Monday, March 03, 2025

Informational:

1 Misc

12/17/24 Tuesday JMJ (Selby Construction - Tucker)  
Mandrel test passed MHA-10 to A9, A9 to A8, A8 to A7

2-26-25 BR Selby Excavation preformed a mandrel test on MH B-1 to MH B-2 on 24" PVC line passed.

3-3-25 BR Selby Excavation preformed a mandrel test on MH B-2 to MH B-3 on 24" PVC line passed.

**Comments:**