

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|---------------|----------|-------------------------|
| Sanitary Sewer - Mandrel | Bobby Richest | Partial | Tuesday, April 29, 2025 |

Informational:
1 Misc

12/17/24 Tuesday JMJ (Selby Construction - Tucker)
Mandrel test passed MHA-10 to A9, A9 to A8, A8 to A7

4-28-25 RH. Selby
MH A6-A7 Passed
MH A5-A6 Passed
MH A4-A5 Passed
MH A3-A4 Passed
MH A2-A3 Failed. Mandrel got stuck 5' into the test.

Comments: