

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232899  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Bobby Richest	Partial	Tuesday, April 29, 2025

Informational:

1	Misc	2-26-25 BR Contractor Selby Excavation preformed air test on 24" PVC pipe between MH A-1 to MH A-2 passed.
		4-28-25 RH
		MH A3-A4 Passed
		MH A2-A3 not tested due to mandrel fail

**Comments:**