



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120016, Building Permit - Commercial
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--|------------|----------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| All Rough Inspection - Commercial | John Borns | Partial | Monday, January 09, 2012 |

Partial Correction
1 MISC

WOMEN'S RR WALLS AND CEILING OK TO COVER AFTER
COPPER PIPING IS PERMANENTLY SEPARATED FROM STEEL
FRAMING -- SPRAY FOAM, OR GROMMETS,..

Comments: