

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242856

Address: 1414 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1412 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ryan Heckman	Partial	Tuesday, April 29, 2025

Informational:

1 Misc

4/29/25 RH. South Sidewalk is formed up and approved to pour, contractor was told to replace straw waddles and clean up street. North Sidewalk had oversaturated soil and was holding water, not approved to pour.

**Comments:**