

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244806
Address: 261 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 30, 2025

Corrective Action Required:

1	Misc	-Adjust self closing gates to fully close and latch. - gate on E side of home grade effecting gate closing and opening
---	------	---

Comments: